

# ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC  
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK  
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE  
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lišem 129, 171 02 Praha 8 - Troja

## CERTIFICATE

**No.:** 1060244

**Product:** Euro Safe

**Type:** JE-H(ST)H E30/E60

**Rating:** (1-24pairs) x (0,6; 0,8; 0,9) mm  
Categorisation according to DIN VDE 4102 - 12  
placing on: cable ladder E30, for diameter 0,9 mm E60  
on cable tray E60,  
cable ceiling ledge E30, for diameter 0,9 mm E60

**Ordering firm:** FTC - Fabbrica Trentina Conduttori s.r.l.  
Via Pineta 21/B, 38068 Rovereto (Trento), Italy

**Manufacturer:** FTC - Fabbrica Trentina Conduttori s.r.l.  
Via Pineta 21/B, 38068 Rovereto (Trento), Italy

**Trade mark:**

**The test results are stated in the test-report No.:** 600550-01/01 of: 28.03.2006

**A sample of the product was found to be in conformity with:**  
DIN 4102-12:1998

**The validity of the certificate is limited to:** 31.3.2009

31.3.2006

Prague

Pavel Kudrna  
Certification and Inspection Manager



Stamp



600550-01