

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRUFANSTALT - TSCHHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod lísem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1051187

Product: Power Cables

Type: Eurosafe 180

Rating: (2-5) x (0,5; 1,0; 1,5; 1,75; 2,5) mm²; 300/500 V

Ordering firm: FTC - Fabbrica Trentina Conduttori s.r.l.
Via Pineta 21/B, 38068 Rovereto (Trento), Italy

Manufacturer: FTC - Fabbrica Trentina Conduttori s.r.l.
Via Pineta 21/B, 38068 Rovereto (Trento), Italy

Trade mark:

The test results are stated in the test-report No.: 503852-01/01 of: 07.12.2005

A sample of the product was found to be in conformity with:
ČSN IEC 60331-11:2001, ČSN IEC 60331-21:2001, BS 6387:1994 category C, W, Z

The validity of the certificate is limited to: 31.12.2008

9.12.2005 corrigendum 18.1.2006

Prague

Pavel Kudrna
Certification and Inspection Manager



Stamp



503852-01