



Product Certification Body accredited
by Slovak national accreditation service



FIRES sr.o.
Osloboditeľov 282, 059 35 Batizovce, Slovakia
www.fires.sk



PRODUCT CLASSIFICATION FIRES CR 039/06 SAP

Product: Communication cable **EUROSAFE E30/E60**

Sponsor: **FTC – Fabricca Trentina Conduttori S.R.L.**
Via Pineta 21B
38068 Rovereto, Italy

Manufacturer: **FTC – Fabricca Trentina Conduttori S.R.L.**
Via Pineta 21B
38068 Rovereto, Italy

The product is classified:

Standard No.	Standard designation	Support	Cable	Classification
DIN 4102 – 12: 1998-11	Fire resistance of electric cable systems required to maintain circuit integrity	Steel tray	0,6 mm ² and more, up to 0,9 mm ² (excluding) of the type specified	E 30
			0,9 mm ² of the type specified	E 60
		Steel ladder	0,6 mm ² and more, up to 0,9 mm ² (excluding) of the type specified	E 30
			0,9 mm ² of the type specified	E 60
		Ceiling ledges with clamps	from 0,6 mm ² to 0,9 mm ² of the type specified	E 60

Note: The classification is only applicable to cables of specified type and for specified cross-sections, and to any number of conductors within a cable.

The test details are described in test report No.: **FIRES FR 014/06 CS** (project No. K-05/249-05/209)

The cables were laid in supporting system OBO BETTERMANN. The classification is valid for other types of supporting systems on condition that provisions of DIN 4102-12 concerning standard supporting systems are met.

Note:

- Validity of this document expires on 17th February 2011.
- Any changes to this document may only be made by FIRES s.r.o. Batizovce, Slovak Republic.

Batizovce 17th February 2006

Prepared by:

Ing. Miroslav Smolka, MBA
head of testing laboratory



Issued by:

Ing. Štefan Rástocký
head of product certification body